

ADDENDUM NO. 1
June 17, 2010

TO CONTRACT DOCUMENTS FOR:

CITY OF FALLS CHURCH
TYSONS MARRIOTT SYSTEM IMPROVEMENTS
June 2010
IFB 0518-10-TMWM

This addendum forms a part of the contract documents and clarifies the contract documents as stated herein. This addendum must be acknowledged in the space provided in the proposal. Failure to acknowledge shall subject the Bidder to disqualification.

Except as may be otherwise described, bidding requirements, materials, and workmanship for the work described herein shall conform to all requirements of the original Contract Documents. The following Addendum to the drawings and specifications is made a part of the project, and takes precedence over the section of the specifications, in part, originally written and over the drawings, in part, as originally drawn and/or written.

This addendum consists of 4 pages, including attachments.

Attachment:

Pre-bid Meeting Attendee and Agenda

Pre-bid Meeting Minutes

The non-mandatory Pre-bid Meeting was conducted on June 17, 2010. The attendees are listed on the attached Agenda and Attendee exhibit. The items outlined in the attached Agenda were covered. Responses to Bidder's questions and/or items presented by the City of Falls Church at the Pre-bid Meeting are addressed below, and as required in the following revisions to the project manual, for those items that required further clarification.

Questions Received

Question What is the type of pipe used?

Answer Ductile Iron Pipe

Question Is there any jacking and boring or directional boring associated with the Installation of pipes?

Answer There is a 135' jack and bore required for this project.

Question What is the approx. cost estimate for the whole project?

Answer It is anticipated that the bids will be less than 5500,000.

Question Are there any minority set-aside requirements for this project?

Answer No

Question When is the last day to receive questions?

Answer: Close of Business on June 30, 2010

Revisions to the Project Manual:

NONE

Revisions to Plan Set:

NONE

END OF ADDENDUM NO. 1

The City of Falls Church is committed to the letter and spirit of the Americans with Disabilities Act. To request a reasonable accommodation for any type of disability call 703 248-5007, (TTY 711).

The City of Falls Church does not discriminate against faith-based organizations in accordance with the Code of Virginia, § 2.2-4343.1 or against any bidder or offeror because of race, religion, color, sex, national origin, age, disability, or any other basis prohibited by state law relating to discrimination in employment.



CITY OF FALLS CHURCH

Tysons Marriott Water System Improvements Pre-Bid Meeting Agenda June 17, 2010 10.00 AM

Attendees

- Flippo Construction
- R.L. Rider
- Arthur Construction

1. Introduction
2. Project Overview
 - a. Location
 - b. Staging Area
 - c. VDOT Permit
 - d. Project Duration
 - e. Liquidated Damages
 - f. Specifications
3. Instructions To Bidders
 - a. Bid Package
 - b. Bid Submission
 - c. Bid Opening
 - d. Basis of Award
 - e. Acceptance or Rejection of Bids
4. Questions
5. Site Visit (if requested)

Henry E. Wells Building • 300 Park Avenue • Falls Church, Virginia 22046 • 703-248-5001

www.fallschurchva.gov